



By Precisionviews - Own work, CC BY-SA 4.0, <https://commons.wikimedia.org/w/index.php?curid=83229785>

SPRI Wind Design Seminar

FM Approvals – FM Global



LPDS 1-28 & 1-29



FM Wind Uplift

Design Resources

- www.roofnav.com
- FM PLPDS 1-28 (2024)
- FM PLPDS 1-29 (2022)
- ASCE 7 2005
- ASCE 7 2016



FM PLPDS 1-28

FM Insured Building's pressures should be determined by using Rating Calculator on FM RoofNav Website www.roofnav.com

Note that this is not part of the building code and is not a consensus standard

- Calculations Formula based on ASCE 7-05
- Wind Map based on ASCE 7-05 (100-yr MRI)
- Results are Allowable Stress Design (ASD)
- Safety Factor x2
- GCp based on ASCE 7-16
- Roof Zones based on ASCE 7-16

FM PLPDS 1-28

January 2024. Interim revision. The following changes were made:

A. The tornado guidance formerly in Appendix D has been transferred to new Sections 2.11 and 3.12, and to existing Section 4.2. All tables, figures and equations have been re-numbered to the new sections. Appendix D has been deleted in its entirety.

B. Guidance on FM Approved Roof Anchors was added to Sections 2.6 and 3.8. FM Approved Roof Anchors are now available and can be used to provide additional securement for roof mounted equipment to prevent overturning.

C. Modifications were made to the pressure coefficient for the vertical force equation in Section 2.6. Conditions where the ratio of the distance of elevated roof mounted equipment from the roof surface to the bottom of the equipment in relation to the mean roof height for the building (C/H) is ≥ 0.03 allows for a lower pressure coefficient.

D. The map in Figure 11-b "Basic wind speeds for areas in Canada in a tropical cyclone prone region" was added and replaces certain select cities in Canada within the Canadian Maritimes.

Wind Uplift Load Determination


Key Factors

- Building Height
- Building Location (Local Wind Speed)
- Exposure Category (B, C, or D)
- Importance Category III/IV
- Openings (Partial or Enclosed)



FM PLPDS 1-28 Wind Map

(3 sec Peak Gust Wind)



Importance Categories (Building Use)

Importance Category I – Low risk to human life (Agricultural or storage)

Importance Category II – Not I, III, & IV (Commercial Buildings)

Importance Category III/IV – Substantial risk to human life
(Schools, Public Buildings, Hospitals, Power Plants, etc.)

Importance Factor I = 1.15

ASCE 7-05

Velocity Pressure Formula

$$q_z = 0.00256 \times K_Z \times K_{Zt} \times K_d \times V^2 \times I$$

Variable	Building	ASCE 7-05
K _z	Height & Terrain (40' Exp C)	1.04
K _{zt}	Topography	1
K _d	Wind Directionality	0.85
V	100-yr MRI Winds	90 mph
I	Importance Cat III/IV	1.15
q _z	Results	21.08

$$P = q_z \{ GC_p - GC_{pi} \}$$

ASCE 7-16

Roof Zone GCp Coefficients

Roof Zones for Bldgs. < 90'	ASCE 7-16 GCp Coefficient
Zone 1'	0.9
Zone 1	1.7
Zone 2	2.3
Zone 3	3.0

Roof Zones for Bldgs. ≥ 90'	ASCE 7-16 GCp Coefficient
Zone 1'	N/A
Zone 1	1.4
Zone 2	2.3
Zone 3	3.0

Factory Mutual's Adaptation of ASCE 7-16

GCpi = internal pressure coefficient

Opening Types	Amount of Openings	ASCE 7-16 GCpi Coefficient
Enclosed	Less than 10%	.18
Partially Enclosed	10% or greater openings	.55

$$P = qz (GCp - GCpi) * SF$$

Roof Area	qz	GCp	GCpi	Safety Factor	Result (lbs/sqft)	FM Rating
Zone 1'	21.08	-0.9	0.18	2	-45.5	60
Zone 1	21.08	-1.7	0.18	2	-79.3	90
Zone 2	21.08	-2.3	0.18	2	-104.6	105
Zone 3	21.08	-3.0	0.18	2	-142.5	150

Example Results ASCE 7-05 & ASCE 7-16 vs. FM 1-28

Charlotte, NC

		ASCE 7-05	ASCE 7-16	FM PLPDS 1-28
40-ft high	Local Wind Speed	90 mph	124 mph	90 mph
Exposure "C"	Zone 1'	N/A	21 psf	60 psf
Enclosed Bldg	Zone 1	25 psf	39 psf	90 psf
Category IV	Zone 2	42 psf	52 psf	105 psf
	Zone 3	63 psf	71 psf	150 psf


FM PLPDS 1-29

This is not part of the building code and is not a consensus standard, nor has it been adopted by the Florida Building Code


- Prescriptive Criteria is based on Zone 1, not Zone 1'
- Prescriptive Criteria Limitations:
 - Zone 1 Rating \leq **1-90** (90-psf)
 - Zone 1 Rating \leq **1-105** (105-psf) and in a Non-Tropical Cyclone-Prone Region
- Prescriptive enhancements redefined
 - Insulation securement for adhered roof covers:
 - Fasteners & Adhesives
 - Roof cover securement for mechanically attached roof covers:
 - Linear in-seam
 - Induction Welded

Roof Zone Layout

h = roof height (ft)



$h < 90'$



$a = 10\%$ of the lesser horizontal dimension, but not less than 3ft. (0.9m)

$h \geq 90'$

Adhered Membrane Prescriptive Enhancement Fastened Insulation

Zone 2: 50% more fasteners and plates than the field, but not less than 1 fastener 2 ft² and not more than 1 fastener per 1 ft²




Zone 3: 1 fastener per 1 ft²

Example

Zone 1: 8 per 4' x 8' board (1 fastener per 4 ft²)

Zone 2: The larger of +50% of 8 per board (12) or 1 fastener per 2 ft² (16)

Zone 3: 1 fastener per 1 ft² (32)



Adhered Membrane Prescriptive Enhancement


Adhesive Ribbon Spacing

Adhered membrane with substrate adhered in ribbons

Zone 2: 67% closer ribbons spacing than the field (rounded down)

Zone 3: 50% closer ribbon spacing than the field (rounded down)

Example: Zone 1: 12 inches, Zone 2: 8 inches, Zone 3: 6 inches



Mechanically Fastened Membrane Prescriptive Enhancements

Zone 2 and Zone 3 – In-Seam Attachment Option 1


Zone 2: Row spacing no greater than 67% of the field rows

Zone 3: Row spacing no greater than 50% of the field rows

Example: Zone 1: 7.5 ft

Zone 2: $(7.5 \times .67) = 5$ ft

Zone 3: $(7.5 \times .5) = 3.75$ ft



Mechanically Fastened Membrane Prescriptive Enhancements

Zone 2 and Zone 3 – In-Seam Attachment Option 2

Note: This option is similar to ANSI/SPRI WD-1 & RAS 137

- Determine Zone 1 Pressure and Uplift Rating of assembly
- The sheet width from the Zone 1 assembly is allowed to reduce proportionally to the wind uplift increases in Zone 2 and Zone 3 respectively, rounded up to the nearest 15 PSF

Example: Zone 1 = -80 psf (uplift rating 90 psf)

Zone 1 roof system is 7.5 ft wide rows at 6 inches (0.5 ft) on center

$$[(\text{Zone 1 Rating}) * (\text{Zone 1 Row})] / (\text{Zone 2 or Zone 3 Rating}) = \text{Zone 2 or Zone 3 Row}$$

Zone 2: Example Results: $(90 * 7.5) / 105 = 6.43$ ft. rows

Zone 3: Example Results: $(90 * 7.5) / 150 = 4.5$ ft. rows

Mechanically Fastened Membrane Prescriptive Enhancements

Induction Weld

Plate & Fastener Density for Membrane Induction Weld

Zone 2: Reduce fastener contributory area to 67% of Zone 1

Zone 3: Reduce fastener contributory area to 50% of Zone 1

Zone 1 Fastening Rate: 1 fastener per 5.33 sq. ft. = 6 per board

Zone 2 Fastening Rate=5.33*0.67=3.57 sq. ft. per fastener

32 sq. ft. per board/3.57 = 9 per board

Zone 3 Fastening Rate=5.33*0.5=2.67 sq. ft. per fastener

32 sq. ft. per board/2.67 = 12 per board